



CERTIFICATE OF ACCREDITATION

The ANSI National Accreditation Board

Hereby attests that

**AVO Diagnostic Services
3430 Progress Drive, Unit B
Bensalem, PA 19020**

Fulfills the requirements of

ISO/IEC 17025:2017

In the field of

TESTING

This certificate is valid only when accompanied by a current scope of accreditation.

The current scope of accreditation can be verified at www.anab.org

SCOPE OF ACCREDITATION TO ISO/IEC 17025:2017

AVO Diagnostic Services

3430 Progress Drive, Unit B
Bensalem, PA 19020

Amy Turk
262-408-5932

TESTING

Valid to: **May 6, 2024**

Certificate Number: **L2303.02**

Chemical


Specific Tests and/or Properties Measured	Specification, Standard, Method, or Test Technique	Items, Materials or Product Tested	Key Equipment or Technology
Dielectric Breakdown	ASTM D1816	High voltage fluid	VDE Electrodes
Dielectric Breakdown	ASTM D877	High voltage fluid	Disk Electrodes
Relative Density	ASTM D4052	High voltage fluid	Density meter
Acid Number	ASTM D974	High voltage fluid	Titration
Visual Examination	ASTM D1524	High voltage fluid	Visual Only
ASTM Color of Petroleum Products	ASTM D1500	High voltage fluid	ASTM Color Scale
Dissolved Moisture Content	ASTM D1533	High voltage fluid	Coulometric Karl Fischer
Interfacial Tension	ASTM D971	Mineral and Ester Fluids	Tensiometer
Power Factor (Dissipation Factor) at 25°C to 100°C	ASTM D924	High voltage fluid - Does not apply to Perchloroethylene or Askarel fluids over 25°C	Tan delta and resistivity tester
Dissolved Gas Analysis	ASTM D3612C	High voltage fluid	GC – FID/TCD

Chemical

Specific Tests and/or Properties Measured	Specification, Standard, Method, or Test Technique	Items, Materials or Product Tested	Key Equipment or Technology
Color of Clear Electrical Insulating Liquids (Platinum-Cobalt)	ASTM D2129	High voltage fluid	Platinum-Cobalt Color Scale
Dielectric Breakdown	ASTM D1816	High voltage fluid	VDE Electrodes

Note:

1. This scope is formatted as part of a single document including Certificate of Accreditation No. L2303.02.
2. Megger Systems and Services Inc. dba AVO Diagnostic Services.



Jason Stine, Vice President

